

4. SETUP MODE

Note: Configuration must be completed before adjusting Setup parameters.
 First select Setup mode from Select mode (refer to section 2). The Setup LED will light while in Setup mode. Press to scroll through the parameters, then press to set the required value.
 To exit from Setup mode, hold down and press to return to Select mode.
Note: Parameters displayed depends on how instrument has been configured.

Parameter	Lower Display	Upper Display Adjustment Range & Description	Default Value
Limit Setpoint value	SP	Scaled Range Minimum to scaled Range Maximum	R/max if $Ctrl=H$, R/min if $Ctrl=Lo$
Limit Hysteresis	HYSt	1 LSD to full span in display units, on the safe side of the limit SP	1
Input Filter Time Constant	FiLt	OFF or 0.5 to 100.0 secs (see <i>CAUTION note below</i>)	2.0
High Alarm 1 value	PhA1	Scaled Range Minimum to scaled Range Maximum	R/max
Low Alarm 1 value	PLA1		R/min
Deviation Alarm 1 Value	dAL1	\pm Span from SP in display units	5
Band Alarm 1 value	bAL1	1 LSD to span from setpoint	5
Alarm 1 Hysteresis	AHY1	1 LSD to full span in display units	1
High Alarm 2 value	PhA2	Scaled Range Minimum to scaled Range Maximum	R/max
Low Alarm 2 value	PLA2		R/min
Deviation Alarm 2 Value	dAL2	\pm Span from SP in display units	5
Band Alarm 2 value	bAL2	1 LSD to span from setpoint	5
Alarm 2 Hysteresis	AHY2	1 LSD to full span in display units	1
Setup Lock Code	SLoc	0 to 9999	10

Note: Operator mode screens follow, without exiting from Setup mode.

CAUTION: An excessively large filter time could significantly delay detection of a limit condition. Set this value to the minimum required to remove noise from the process variable

5. PRODUCT INFORMATION MODE

First select Product information mode from Select mode (refer to section 2). Press to view each parameter. To exit from Product Information mode, hold down and press to return to Select mode.

Note: These parameters are all read only.

Parameter	Lower Display	Upper Display	Description
Input type	In_1	Un_1	Universal input
Option 1 type (fixed)	OPn1	rLY	Latching Limit Relay
Option 2 module type fitted	OPn2	nonE	No option fitted
		rLY	Relay output
		SSr	SSR drive output
		tr_1	Triac output
		L in	Linear DC voltage / current output
Option 3 module type fitted	OPn3	nonE	No option fitted
		rLY	Relay output
		SSr	SSR drive output
		L in	Linear DC voltage / current output
Auxiliary Option A module type fitted	OPnA	dc24	Transmitter power supply
		nonE	No option fitted
Firmware type	FLJ	r485	RS485 communications
		dIG_1	Digital Input for remote reset
Firmware issue	ISS	Value displayed is firmware issue number	
Product Revision Level	PrL	Value displayed is Product Revision level	
Date of manufacture	d0:;;	Manufacturing date code (mmyy)	
Serial number 1	Sn1	First four digits of serial number	
Serial number 2	Sn2	Middle four digits of serial number	
Serial number 3	Sn3	Last four digits of serial number	

6. ERROR/FAULT INDICATIONS

Parameter	Upper Display	Lower Display	Description
Instrument parameters are in default conditions	Goto	ConF	Configuration & Setup required. This screen is seen at first turn on, or if hardware configuration has been changed. Press to enter the Configuration Mode, next press to enter the unlock code number, then press to proceed
Input Over Range	CHH	Normal	Process variable input > 5% over-range as above if Display Strategy = SAFE
Input Under Range	LL	Normal	Process variable input > 5% under-range as above if Display Strategy = SAFE
Input Sensor Break	OPEN	Normal	Break detected in process variable input sensor or wiring as above if Display Strategy = SAFE
Option 1 Error		OPn1	Option 1 module fault
Option 2 Error		OPn2	Option 2 module fault
Option 3 Error		OPn3	Option 3 module fault
Option A Error		OPnA	Option A module fault
Option B Error		OPnb	Option B not used on Limit Controllers this error is shown if any module is fitted

7. OPERATOR MODE

This mode is entered at power on, or accessed from Select mode (see section 2).

Note: All Configuration mode and Setup mode parameters must be set as required before starting normal operations.
 Press to scroll through the parameters.

Upper Display	Lower Display	Display Strategy and When Visible	Description
PV Value	Limit SP Value	d.SP = ErrAb (initial screen)	PV and Limit Setpoint values Read only
Limit SP Value	(Blank)	d.SP = d.SA (initial screen)	Limit Setpoint value Read only
SAFE or rSEt	(Blank) or PV Value	d.SP = SAFE. (Initial Screen)	Displays rSEt and PV if Limit Output is active or SAFE if not active. Read only
High Limit Hold	H.Hd	Ctrl = H	Highest PV value since this parameter was last reset. To reset, press for 5 seconds, display = ---- when reset
Low Limit Hold	LoHd	Ctrl = Lo	Lowest PV value since this parameter was last reset. To reset, press for 5 seconds, display = ---- when reset
Exceed Time Value	t	Always available Format mm.ss to 99.59 then mmm.s (10 sec increments) Shows CHH if ≥ 999.9	Accumulated time of Limit SP exceed conditions since this parameter was last reset. To reset, press for 5 seconds, display = ---- when reset
Active Alarm Status	ALSt	When one or more alarms are active. ALARM indicator will also flash	Alarm 2 active Alarm 1 active Annunciator active

Exceed Condition
 An Exceed Condition is when the Process Variable exceeds the Limit Setpoint value (i.e. PV > SP when set for high limit action, PV < SP for low limit action). The LED is on during this condition, and is extinguished once it has passed.

Limit Output Function
 Limit Output relay(s) de-energize whenever an Exceed condition occurs, causing the process to shut down. The LED is on when the relay is de-energized. The relay remains latched off even if the Exceed condition is no longer present. Only giving a reset instruction (after the exceed condition has passed) will re-energize the relay, allowing the process to continue. The LED then turns off.

Limit Annunciator Outputs
 An Annunciator output will activate when an Exceed condition occurs, and will remain active until a reset instruction is received, or the Exceed condition has passed. Unlike the Limit Output, an Annunciator can be reset even if the Exceed condition is present. When an Annunciator is active, the ALARM LED will flash and the Alarm Status screen is available.

Resetting Limit Outputs & Annunciators
 A reset instruction can be given by pressing the key, via the Digital Input (if fitted) or via a Comms command if an RS485 Communications module is fitted. Annunciators will deactivate. Limit Outputs will only re-energize if the Exceed condition has passed.

CAUTION: Ensure that the cause of the Exceed condition has been rectified before resetting the Limit Output.

8. SERIAL COMMUNICATIONS

Refer to the full user guide (available from your supplier) for details.

9. SPECIFICATIONS

UNIVERSAL INPUT

Thermocouple: $\pm 0.1\%$ of full range, $\pm 1\text{LSD}$ ($\pm 1^\circ\text{C}$ for Thermocouple CJC). Calibration: BS4937, NBS125 & IEC584.
 PT100 Calibration: $\pm 0.1\%$ of full range, $\pm 1\text{LSD}$. BS1904 & DIN43760 ($0.00385/\Omega/^\circ\text{C}$).
 DC Calibration: $\pm 0.1\%$ of full range, $\pm 1\text{LSD}$.
 Sampling Rate: 4 per second.
 Impedance: $>10M\Omega$ resistive, except DC mA (5Ω) and V ($47k\Omega$).
 Sensor Break Detection: Thermocouple, RTD, 4 to 20 mA, 2 to 10V and 1 to 5V ranges only. Limit outputs turn off (goes into Exceed condition), high alarms activate for thermocouple/RTD sensor break, low alarms activate for mA/V DC sensor break.

Isolation: Isolated from all outputs (except SSR driver).
 Universal input must not be connected to operator accessible circuits if relay outputs are connected to a hazardous voltage source. Supplementary insulation or input grounding would then be required.

DIGITAL INPUT

Volt-free(or TTL): Open (2 to 24VDC) = No Reset.
 Closed (<0.8VDC) = Reset (edge triggered).
 Isolation: Reinforced safety isolation from inputs and other outputs.

OUTPUTS

Limit Relay
 Contact Type & Rating: Latching limit control relay. Single pole double throw (SPDT); 5A resistive at 120/240VAC. Slot 1 position fixed for this function, optional function for Slot 2 & 3 relay modules.
 Lifetime: >100,000 operations at rated voltage/current.
 Isolation: Basic Isolation from universal input and SSR outputs.
Alarm Relays
 Contact Type & Rating: Slot 2 or 3 position non-latching alarm relay. Single pole double throw (SPDT); 2A resistive at 120/240VAC.
 Lifetime: >500,000 operations at rated voltage/current.
 Isolation: Basic Isolation from universal input and SSR outputs.
SSR Driver
 Drive Capability: SSR drive voltage >10V into 500 Ω min.
 Isolation: Not isolated from universal input or other SSR driver outputs.
Triac
 Operating Voltage: 20 to 280Vrms (47 to 63Hz).
 Current Rating: 0.01 to 1A (full cycle rms on-state @ 25°C); derates linearly above 40°C to 0.5A @ 80°C.
 Isolation: Reinforced safety isolation from inputs and other outputs.

DC
 Resolution: 8 bits in 250mS (10 bits in 1s typical, >10 bits in >1s typical).
 Isolation: Reinforced safety isolation from inputs and other outputs.
Transmitter PSU
 Power Rating: 20 to 28V DC (24V nominal) into 910 Ω minimum resistance.
 Isolation: Reinforced safety isolation from inputs and other outputs.

SERIAL COMMUNICATIONS
 Physical: RS485, at 1200, 2400, 4800, 9600 or 19200 bps.
 Protocols: Modbus RTU
 Isolation: Reinforced safety isolation from all inputs and outputs.

OPERATING CONDITIONS (FOR INDOOR USE)
 Ambient Temperature: 0°C to 55°C (Operating), -20°C to 80°C (Storage).
 Relative Humidity: 20% to 95% non-condensing.
 Supply Voltage and Power: 100 to 240VAC $\pm 10\%$, 50/60Hz, 7.5VA (for mains powered versions), or 20 to 48VAC 50/60Hz 7.5VA or 22 to 65VDC 5W (for low voltage versions).

ENVIRONMENTAL
 Standards: CE, UL, cUL & FM 3545, 1998
 EMI: Complies with EN61326 (Susceptibility & Emissions).
 Safety: Complies with EN61010-1 & UL3121.
 Considerations: Pollution Degree 2, Installation Category II.
 Front Panel Sealing: To IP66 (IP20 behind the panel).

PHYSICAL

Front Bezel Size: $1/16$ Din = 48 x 48mm, $1/8$ Din = 96 x 48mm, $1/4$ Din = 96 x 96mm.
 Depth Behind Panel: $1/16$ Din = 110mm, $1/8$ & $1/4$ Din = 100mm.
 Weight: 0.21kg maximum.

PK504 0037-75490 December, 2012
